

# Evidence of Performance

Resistancenc to wind load, Watertightness, Air permeability



## Test Report

No. 14-002947-PR01

(PB-A01-02-en-01)

<b>Client</b>	CASA NOASTRA SRL DN 65, Km 13, Pielesti, 207450 Dolj Romania
<b>Product</b>	Tilt and turn Window
<b>Designation</b>	System designation: *)
<b>Performance-relevant product details</b>	Material: PVC-U / white
<b>Overall dimensions (W x H)</b>	1,230 mm x 1,480 mm
<b>Special features</b>	*) According to information given by the manufacturer the used profiles are taken from VEKA AG, System Softline 82. A sampling report has been provided to the ift.

### Basis

EN 14351-1:2006+A1:2010

Test standard/s:


EN 1026:2000-06

EN 1027:2000-06

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

### Representation



### Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

### Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

### Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 23 pages.

## Results

Air permeability according to EN 12207:1999-11



**Class 4**

Watertightness according to EN 12208:1999-11



**Class E1050**

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



**Class C5 / B5**

ift Rosenheim

19.09.2014

Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Construction Product Testing

Andreas Graf, Dipl.-Ing. (FH)  
Operating Testing Officer  
Construction Product Testing

ift Rosenheim GmbH

Theodor-Gietl-Str. 7 - 9  
D-83026 Rosenheim

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14763

Anerkannte Stelle

Notified Body 0757

PUZ-Stelle: BAY 18



Geschäftsführer:  
Dr. Jochen Peichl  
Prof. Ulrich Sieberath

Tel.: +49 (0)8031/261-0  
Fax: +49 (0)8031/261-290  
www.ift-rosenheim.de

Sparkasse Rosenheim  
IBAN: DE907115000000003822  
SWIFT-BIC: BYLADEM1ROS